



Addendum # 1



Date: June 8, 2026
To: All bidders
From: David Williams, Buyer
Solicitation Number: ITB# GRM/260740
Solicitation Title: Construct and Install Bus Stop Shelters

SECTION 1. SOLICITATION - CLARIFICATION

QUESTION 1: From the solicitation, it is unclear if this bid required Electrical drawings signed by a professional engineer. The solicitation only included civil engineering drawings.

ANSWER 1: The City of Ocala will not require Electrical drawings signed by a professional engineer for the solar component of the project. The solar lighting to be a specification included with the shelter order.

SECTION 1. SOLICITATION – PROJECT DETAILS - CLARIFICATION

- All hardware for shelter assembly is provided, any replacement hardware needed must be Stainless Steel.
- Benches shall be placed per the specifications, set to one side of the shelter to allow for mobility devices (wheelchairs)
- Some locations have existing bus benches owned and managed by Creative Outdoor Advertising (COA). Removal must be coordinated with COA, a minimum of a 2-week notice, contact info TBD.
- Shelters have been purchased and are in storage at the SunTran Facility.
- No trash cans will be installed