



Shaw Substation Transformer #4 Foundation Design Calculations


Shaw Substation
Ocala, Florida


Prepared for: Ocala Electric Utilities - OEU
Prepared by: GAI Consultants, Inc.

GAI Project Number: R220058.06

Originated by: Thomas I. Raffaele
Checked by: Kristan T. Johnsen
Approved by: Kristan T. Johnsen

May/2024




	Project Ocala Shaw Substation				Job Ref.	
	Section Transformer #4 Foundation				Sheet no./rev. 1	
	Calc. by KTJ	Date 5/10/2024	Chk'd by	Date	App'd by	Date

WIND LOADING

In accordance with ASCE7-16

Using the directional design method

Tedds calculation version 2.1.13

**Wall/sign data**

Length of wall/sign $B = 20.17$ ft
 Height of wall/sign $s = 15.16$ ft
 Height to top of sign $h = 15.16$ ft

General wind load requirements

Basic wind speed $V = 130.0$ mph
 Risk category II
 Velocity pressure exponent coef (Table 26.6-1) $K_d = 0.85$
 Ground elevation above sea level $Z_{gl} = 0$ ft
 Ground elevation factor $K_e = \exp(-0.0000362 \times Z_{gl}/1\text{ft}) = 1.00$
 Exposure category (cl 26.7.3) B

Gust effect factor for rigid structures


Terrain exposure constants (Table 26.11-1)
 Integral length scale factor $I = 320.0$ ft
 Turbulence intensity factor $c = 0.30$
 Minimum equivalent height $Z_{min} = 30.0$ ft
 Peak factor for background response $g_Q = 3.400$
 Peak factor for wind response $g_v = 3.400$
 Integral length scale power law exponent $\bar{\epsilon} = 0.333$
 Equivalent height of the structure $\bar{z} = \max(0.6 \times h, Z_{min}) = 30.00$ ft
 Intensity of turbulence (Eqn. 26.11-7) $I_{\bar{z}} = c \times (33 \text{ ft} / \bar{z})^{1/6} = 0.30$
 Integral length scale of turbulence (Eqn. 26.11-9) $L_{\bar{z}} = I \times (\bar{z} / 33 \text{ ft})^{\bar{\epsilon}} = 310.00$ ft
 Background response (Eqn. 26.11-8) $Q = \sqrt{(1 / (1 + 0.63 \times ((B + h) / L_{\bar{z}})^{0.63}))} = 0.928$
 Gust effect factor (Eqn. 26.11-10) $G = G_f = 0.925 \times (1 + 1.7 \times g_Q \times I_{\bar{z}} \times Q) / (1 + 1.7 \times g_v \times I_{\bar{z}}) = 0.88$
 Minimum design wind loading (cl.27.1.5) $p_{min_r} = 8 \text{ lb/ft}^2$

Topography

Topography factor not significant $K_{zt} = 1.0$

Velocity pressure

Velocity pressure coefficient (Table 26.10-1) $K_z = 0.57$
 Velocity pressure $q_h = 0.00256 \times K_z \times K_{zt} \times K_d \times K_e \times V^2 \times 1\text{psf/mph}^2 = 21.0 \text{ psf}$

	Project Ocala Shaw Substation				Job Ref.	
	Section Transformer #4 Foundation				Sheet no./rev. 2	
	Calc. by KTJ	Date 5/10/2024	Chk'd by	Date	App'd by	Date

Area of sign

$$A_f = B \times s = 305.777 \text{ ft}^2$$

Ratio of solid area to gross area

$$\varepsilon = 1.00$$


Wall/sign forces – Case A and B

Force coefficient (Figure 29.3-1)


$$C_{f,A} = 1.43$$

Resultant force


$$F_A = \max(16\text{psf}, q_h \times G_f \times C_{f,A}) \times A_f = 8.1 \text{ kips}$$



Plan - Case A



Plan - Case B

	Project Ocala Shaw Substation				Job Ref.	
	Section Transformer #4 Foundation				Sheet no./rev. 1	
	Calc. by KTJ	Date 5/10/2024	Chk'd by	Date	App'd by	Date

BEARING PRESSURES FOR RECTANGULAR FOOTINGS


Tedds calculation version 1.0.05

Design summary

Description	
Four corners are in bearing	
100 % of footing area is acting in bearing	
Maximum bearing pressure is 1.481 kips/ft ²	

Footing details

Length of footing	Lx = 15 ft
Width of footing	Ly = 9 ft
Total base reaction	Pz = 150 kips
Eccentricity of base reaction in x-axis	ex = 0 ft
Eccentricity of base reaction in y-axis	ey = 0.5 ft

**Corner base pressures**

$$q_1 = Pz \times (1 - 6 \times ex / Lx - 6 \times ey / Ly) / (Lx \times Ly) = \mathbf{0.741 \text{ kips/ft}^2}$$

$$q_2 = Pz \times (1 - 6 \times ex / Lx + 6 \times ey / Ly) / (Lx \times Ly) = \mathbf{1.481 \text{ kips/ft}^2}$$

$$q_3 = Pz \times (1 + 6 \times ex / Lx - 6 \times ey / Ly) / (Lx \times Ly) = \mathbf{0.741 \text{ kips/ft}^2}$$

$$q_4 = Pz \times (1 + 6 \times ex / Lx + 6 \times ey / Ly) / (Lx \times Ly) = \mathbf{1.481 \text{ kips/ft}^2}$$

Maximum bearing pressure

$$q_{\max} = \max(q_1, q_2, q_3, q_4) = \mathbf{1.481 \text{ kips/ft}^2}$$

Percentage of footing area acting in bearing

$$\text{BearingPercentage} = \mathbf{100 \%}$$