



Addendum # 2



Date: March 6, 2026
To: All bidders
From: Caley Conard, Buyer
Solicitation Number: ITB# PWD/260492
Solicitation Title: Stormwater Aquatic and Right of Way Weed Control

SECTION 1. QUESTIONS AND ANSWERS

1.1 **QUESTION: Are the only herbicides allowed the ones listed on the “Additional Herbicide Pricing” list?**

ANSWER: No. The herbicides listed on the “Additional Herbicide Pricing” list are not exclusive. The Contractor may use any herbicides they deem appropriate for the required services.

SECTION 2. SOLICITATION ADDITIONS, CLARIFICATIONS AND CORRECTIONS

- 2.1 Each pond must be inspected at least once per month. If a pond does not require treatment during a given month, the Contractor will still invoice for that pond. Some ponds may require more frequent maintenance to bring excessive vegetation growth under control.
- 2.2 DRA #59 is a high-flow pump station and requires consistent and proactive treatment, particularly for hydrilla. If hydrilla is not adequately controlled, it can obstruct the pumps during high-flow events and compromise system operation.
- 2.3 Once each year, during the winter season, the City will draw down certain DRAs to allow for enhanced vegetation treatment.