



Addendum # 2



Date: June 25, 2024
To: All bidders
From: Eileen Marquez, Senior Buyer
Solicitation Number: ITB# ENG/250425
Solicitation Title: Water Treatment Plant No. 2 GST No. 1 Construction

SECTION 1. SOLICITATION ADDITIONS, CLARIFICATIONS AND CORRECTIONS

1.1 The following exhibits have been added:

- **NEW 3.25.25 Exhibit I - Geotechnical Investigation Report- Ocala WTP 2**
NEW Exhibit G -Plan Set #2.
- **NEW 3.25.25 Exhibit J - Confirmation of Geotechnical Recommendation - Ocala WTP 2.**
- **NEW 3.25.25 Exhibit I - Geotechnical Investigation Report- Ocala WTP 2.**

1.2 The following exhibits have been added:

- **Notice to Proceed (NTP) must be signed within 90 days of City Council approval.**

1.3 Electrical information clarification:

There is no electrical conduit or wiring needed beyond the grounding and lightning protection. Additional instruments and future conduits up the tank will be installed under a future separate project.