



# Addendum # 4



**Date:** May 7, 2026  
**To:** All bidders  
**From:** Caley Conard, Buyer  
**Solicitation Number:** ITB# WRS/260536  
**Solicitation Title:** WRF #2 Rotary Press

## SECTION 1. QUESTIONS AND ANSWERS

1.1 **QUESTION:** The project summary in exhibit A says that the vendor shall supply a “liquid polymer mixing system”. During the pre-bid meeting it was stated that the existing polymer system which is in place for the existing belt press can be used for the new fan press. Please confirm that if the fan press manufacturer confirms the existing polymer system is adequately sized for the proposed equipment, a new polymer system is NOT required as part of this project

ANSWER: Correct. If the manufacturer confirms that the existing polymer system is adequately sized, we will not need a new polymer system.

1.2 **QUESTION:** Please also confirm that the City of Ocala will handle all wiring between the new fan press and the existing polymer system, and that the City will handle all SCADA integration for these systems.

ANSWER: The City will assist on the power installation and SCADA integration.

## SECTION 2. SOLICITATION ADDITIONS, CLARIFICATIONS AND CORRECTIONS