



Addendum # 2



Date: March 30, 2026
To: All bidders
From: Eileen Marquez, Senior Buyer
Solicitation Number: ITB# CIP/260548
Solicitation Title: CONSTRUCT- Auxiliary Apparatus Storage for Fire Station #7

SECTION 1. QUESTIONS AND ANSWERS

1.1 **QUESTION: What are the specs to pave past the 5' open cuts to patch in road?**

ANSWER: See NEW Exhibit E – Trench Width Pavement Replacement from the City of Ocala Standard Detail Specification Book, added to the solicitation. The contractor shall repair the full width of the open cut and mill and replace up to 10' feet on either side of the cut.