



Addendum # 1



Date: June 17, 2026
To: All bidders
From: Eileen Marquez, Senior Buyer
Solicitation Number: ITB# FAC/260769
Solicitation Title: Administration Remodel - City of Ocala Fiber Network

SECTION 1. QUESTIONS AND ANSWERS

1.1 QUESTION: Please clarify the required panel signage called out on A100, including the quantity, dimensions, and material requirements.

ANSWER: This signage is only for needed areas like restrooms and exits. The detail lists size and material requirements.

SECTION 2. SOLICITATION ADDITIONS, CLARIFICATIONS, AND CORRECTIONS

2.1 The following quantities were requested by vendors during the Pre-Bid Meeting held this morning. These figures are being provided for informational and estimating purposes only. Vendors are responsible for verifying all quantities and field conditions as part of their bid preparation.

- **Door Count:** 39 total doors
- **Lighting Fixtures:** 97 total light fixtures to be replaced
- **Baseboard:** 1,831 linear feet

2.2 The City will run the cables in the Networking Room. The vendor will run cables from current area into the newly built server room, the City will make final connections.

2.3 The existing A/C will remain in place but the vent will be moved to another location as per the provided drawing.

2.4 Existing door locations will remain the same, all frames and doors will be replaced as per the scope of work.

2.5 No video, security or speakers are required.

2.6 The flooring will be provided by the City at a later date, for vendor to install, baseboard color will be decided before the painting phase begins.

2.7 A barrier may be required in certain areas during construction.

2.8 A bid bond is required for this solicitation.

2.9 See the **NEW Exhibit C – Server Room Addition** drawing, which has been added to the solicitation. The newly added server room should be incorporated into your bid review and pricing, as applicable.

NEW Exhibit C - Server Room Addition

CONTRACT# FAC/260769

