



# Addendum # 2



**Date:** June 25, 2024  
**To:** All bidders  
**From:** Eileen Marquez, Senior Buyer  
**Solicitation Number:** ITB# CIP/240746  
**Solicitation Title:** North Complex Trailer Yard Shed

## SECTION 1. SOLICITATION ADDITIONS, CLARIFICATIONS AND CORRECTIONS

- 1.1 The Contractor shall acquire a plumbing permit along with the building and electric permits.
- 1.2 Approved electrical fixtures:
  - a) **Light switch** - in NEMA-#R rated 1-Gang metal box mounted to panel at 48" AFF with weatherproof "Flip-Lid" cover plate.
  - b) **Receptacle** - in NEMA 3R rated 2-Gang box (MTD. 48" AFF) with common weatherproof Flip-Lid cover plate.
  - c) **Lights** - 4'L. Surface Mounted L.E.D. Industrial type light fixture with specification grade steel housing, white baked enamel finish, 7000 lumen/3500K LED package, universal voltage driver, wide throw optics, and heavy duty wire guard; Metalux 4 ILED-LED5—7-W-WG-UNV-L835-1.