



# Addendum # 2



**Date:** July 31, 2024  
**To:** All bidders  
**From:** Louis Joseph, Buyer  
**Solicitation Number:** ITB# CDS/240234  
**Solicitation Title:** **Residential Rehabilitation - Johnson**

## SOLICITATION ADDITIONS, CLARIFICATIONS, AND CORRECTIONS

**NOTE: ALL INSTALLATIONS OR REPLACEMENTS MUST INCLUDE NEW PRODUCTS OR MATERIALS.**

### ITEM 1-Roof

14) **Provide and install, code-compliant, asphalt shingles**, a minimum 130 MPH wind rating, and a minimum 30-year warranty. Flat roofs use a RUBEROID® torch system equal or better. The owner will choose the color following the contract signing, and the rehab specialist must approve it. (Lighter, Energy Star colors suggested). [If code requires, install code-compliant metal roofing, 26ga w/ WoodZac Lifetime Warranty Panel Screws.](#)