Addendum # 1

Date:	October 28, 2026
To:	All bidders
From:	Caley Conard, Senior Buyer
Solicitation Number:	ITB# ELE/270026
Solicitation Title:	Underground Boring and Conduit Installation Services

SECTION 1. QUESTIONS AND ANSWERS

1.1 **QUESTION: What is the maximum time the contractor is responsible for maintaining the installed conduit before cable Installation? Assuming that the cable installation is significantly delayed**

ANSWER: The contractor is responsible for the conduit until wire is installed.

1.2 **QUESTION: Pertaining to the 10ft of PVC installed prior to any turn up referenced in the specifications, under what item will the contractor be compensated for the open excavation, material, associated labor?**

ANSWER: The contractor is compensated for each stub-up separate from price per foot. That should cover excavation and material.

SECTION 2. SOLICITATION ADDITIONS, CLARIFICATIONS AND CORRECTIONS

N/A