CSW 724
Closed
824

L10030

ABC
10/T
L4390

L4392

L10015

L4391

L10562
42'/? ( ) V

76

3" Conduit 198'

L10032

4647

C
15/K
L3056

L10561
42'/? ( ) V

75

3" Conduit 191'

L10033

PRIVATE DR

L3611

L3435

L4713

ABC
40/K
L3057

L10560
42'/? ( ) V

74

3" Conduit 175'

123 124
119 120
121 122
117 118

ABC

L10051

211 212
203 208
201 202 210

223 224
219 216
217 218 222
213

231 236
227 228
229 230
225

L10049

BLDG 100

BLDG 200

L10042
ABC

L10039

L10040
ABC

AB
65/K

L10559
42'/? ( ) V

73

BLDG 300

L10053

330 325
334 333
332 327
336 335

318 313
322 321
324 319 323

306 305
310 309
308 307
312 311

L10054

36

8-10-12', 12', 3/8"

L10035
50'/1 ( ) V

L10055

4850

L10558
42'/? ( ) V

72

3" Conduit 199'

423 424
419 420
421 416
417 418

435 436
431 432
433 434
429 430

407 412
409 410
405 406

L10058

L10056

BLDG 400

35

L10317
50'/1 ( ) V

L10043
ABC

L10557
42'/? ( ) V

71

3" Conduit 90'

Open Point
ABC Open

L10059

O F

L10060

BLDG 500

513
521
519
523

506
510
508
512

505
509
511

BLDG600

614 613
622 621
624 619 623

602 605
606 609
608 607
612 611

L10556

70

34

L10316
50'/1 ( ) V

L10045
ABC

L10046
ABC

33

L10315
50'/1 ( ) V

L10061
ABC

L10236

BLDG 700

706 705
710 709
704
708 711

L10065
ABC

830 829
834 833
832 827
836 835

BLDG 800

814 813
818 817
816 819
820 823

802 801
806 805
810
812 807
811

L10066

32

L10314
50'/1 ( ) V

31

L10296
50'/1 ( ) V

30

L10295
50'/1 ( ) V

L5083

29

L10294
50'/1 ( ) V

SW 40TH AVE

L5084

5127

L5086

L5085

L5087

28

L10293
50'/1 ( ) V

37

L10378
42'/? ( ) V

3" Conduit 167'

27

L10292
50'/1 ( ) V

SW NB I75

Install 6" Primary Conduit From:
- WL3 to WL66 ~ 118' (Riser Pole to Primary Cabinet)
- WL5 to WL63 ~ 118' (Riser Pole to Primary Cabinet)
- WL12 to WL53 ~ 255' (Riser Pole to Primary Cabinet)
- WL23 to WL41 ~ 150' (Riser Pole to Existing Switchgear)
- WL53 to WL57 ~ 744' (Primary Cabinet to Primary Cabinet)
- WL57 to WL61 ~ 594' (Primary Cabinet to Primary Cabinet)
- WL61 to WL63 ~ 297' (Primary Cabinet to Primary Cabinet)
- WL63 to WL66 ~ 462' (Primary Cabinet to Primary Cabinet)

Install 3" Primary Conduit From:
- WL7 to WL60 ~ 199' (Riser Pole to UG Transformer)
- WL21 to WL47 ~ 118' (Riser Pole to UG Transformer)

Install 3" Streetlight Conduit From:
- WL37 to WL38 ~ 167' (SL Vault to SL Vault)
- WL38 to WL39 ~ 153' (SL Vault to SL Vault)
- WL39 to WL40 ~ 160' (SL Vault to SL Vault)
- WL40 to WL69 ~ 135' (SL Vault to SL Vault)
- WL42 to WL69 ~ 193' (SL Vault to SL Vault)
- WL42 to WL43 ~ 153' (SL Vault to SL Vault)
- WL43 to WL47 ~ 73' (SL Vault to UG Transformer)
- WL44 to WL47 ~ 69' (SL Vault to UG Transformer)
- WL44 to WL45 ~ 140' (SL Vault to SL Vault)
- WL45 to WL46 ~ 160' (SL Vault to SL Vault)
- WL46 to WL48 ~ 189' (SL Vault to SL Vault)
- WL48 to WL49 ~ 207' (SL Vault to SL Vault)
- WL49 to WL50 ~ 227' (SL Vault to SL Vault)
- WL50 to WL51 ~ 229' (SL Vault to SL Vault)
- WL52 to WL53 ~ 221' (SL Vault to SL Vault)
- WL53 to WL54 ~ 210' (SL Vault to SL Vault)
- WL54 to WL55 ~ 175' (SL Vault to SL Vault)
- WL55 to WL56 ~ 222' (SL Vault to SL Vault)
- WL56 to WL58 ~ 243' (SL Vault to SL Vault)
- WL58 to WL59 ~ 180' (SL Vault to SL Vault)
- WL59 to WL60 ~ 215' (SL Vault to UG Transformer)
- WL60 to WL60 ~ 10' (UG Transformer to SL Vault)
- WL60 to WL62 ~ 250' (SL Vault to SL Vault)
- WL62 to WL64 ~ 238' (SL Vault to SL Vault)
- WL64 to WL65 ~ 231' (SL Vault to SL Vault)
- WL65 to WL67 ~ 223' (SL Vault to SL Vault)
- WL67 to WL68 ~ 203' (SL Vault to SL Vault)
- WL67 to WL68 ~ 203' (SL Vault to SL Vault)
- WL70 to WL71 ~ 90' (UG Transformer to SL Vault)
- WL71 to WL72 ~ 199' (SL Vault to SL Vault)
- WL72 to WL73 ~ 191' (SL Vault to SL Vault)
- WL73 to WL74 ~ 175' (SL Vault to SL Vault)
- WL74 to WL75 ~ 191' (SL Vault to SL Vault)
- WL75 to WL76 ~ 198' (SL Vault to SL Vault)

AS BUILT

DATE

DATE

LOCATES: YES

N
W E
S

1 " = 75 '

SW 40th/SW 49th Ave - New Feeder

Install new feeder extention along SW 40th/SW 49th Ave on Circuit 824.

OCALA
Find your place

1805 NE 30 AVE
OCALA, FL 34470
PH: (352) 351-6620
FX: (352) 401-6961

Prj #Project Number	CKT:	824	SW 40th Ave Ocala, FL
WO #: EP22-179	ENG:	lking	
	DATE:	10/28/2025	