



Addendum # 1



Date: January 15, 2026
To: All bidders
From: Louis Joseph, Buyer
Solicitation Number: RFQ# CDS/260363
Solicitation Title: **Roof Replacement - Stokes**

SOLICITATION ADDITIONS, CLARIFICATIONS, AND CORRECTIONS

NOTE: ALL INSTALLATIONS OR REPLACEMENTS MUST INCLUDE NEW PRODUCTS OR MATERIALS.

ITEM 1 - Roof

1. The Simpson H2.5 hurricane clips will not be required. However, after soffit removal, Contractor will need to ensure that existing straps have a minimum of three (3) fasteners.
2. The Wind Mitigation form is still required.