



# Addendum # 1



**Date:** January 20, 2026  
**To:** All bidders  
**From:** Louis Joseph, Buyer  
**Solicitation Number:** RFQ# CDS/260364  
**Solicitation Title:** **Roof Replacement - Burry**

## SOLICITATION ADDITIONS, CLARIFICATIONS, AND CORRECTIONS

**NOTE: ALL INSTALLATIONS OR REPLACEMENTS MUST INCLUDE NEW PRODUCTS OR MATERIALS.**

### ITEM 1 - Roof

1. Turbo Vents must be removed.
2. The Contractor must verify roof layers.
3. The Contractor shall remove the gas chimney vent
4. Gutter with the downspouts must be installed across the front of the home
5. The gutter at the SE side of the roof must be installed from the corner of the porch to the end of the roof.
6. The cobra vent must be installed on the ridge, and the maximum amount of ridge vent shall be installed.
7. The H2.5 clips are not required. The Contractor must verify that each strap has 3 fasteners and shall add fasteners as necessary.
8. The Wind Mitigation form is required and signed by a qualified inspector.