



Addendum # 1



Date: January 28, 2026
To: All bidders
From: Louis Joseph, Buyer
Solicitation Number: RFQ# CDS/260362
Solicitation Title: **Roof Replacement - Martin**

SOLICITATION ADDITIONS, CLARIFICATIONS, AND CORRECTIONS

NOTE: ALL INSTALLATIONS OR REPLACEMENTS MUST INCLUDE NEW PRODUCTS OR MATERIALS.

ITEM 1 - Roof

1. Contractor shall add 2x6 wood facia to the end of rafters throughout.
2. 1by under drip edge can be removed before installing new wood and aluminum fascia.
3. All new decking installed shall be numbered and photographed before covering.
4. Numbers must be clearly legible.