



Addendum # 1



Date: February 17, 2025
To: All bidders
From: Louis Joseph, Buyer
Solicitation Number: RFQ# CDS/250400
Solicitation Title: **Roof Replacement - Ingram**

SOLICITATION ADDITIONS, CLARIFICATIONS, AND CORRECTIONS

NOTE: ALL INSTALLATIONS OR REPLACEMENTS MUST INCLUDE NEW PRODUCTS OR MATERIALS.

ITEM 1 - Roof

1. Skylight shall remain. The Skylight is currently not leaking but can be replaced if necessary.
2. The Fasteners for the hurricane clips shall be rated for the material to which it will be installed. (Wood or Masonry) minimum embedment shall be according to manufacturer specification.
3. The Gutter must have downspout/s. All downspouts shall have a concrete splash block. The Contractor shall assume gutter to be installed across the entire front porch (up to 30' of gutter and two downspouts).