



# Addendum # 1



**Date:** March 3, 2022  
**To:** All bidders  
**From:** Shay Roberts, Senior Buyer  
**Solicitation Number:** RFQ# GRM/220083  
**Solicitation Title:** Downtown Parking Garage Deep Clean and Pressure Wash

## SECTION 1. SOLICITATION ADDITIONS, CLARIFICATIONS AND CORRECTIONS

1. In accordance with the Florida Department of Environmental Protection Recommended Best Management Practices any runoff water from pressure cleaning of the parking garage will need to be contained and not enter the storm system.
2. Vendor must have a portable water reclaim system in order to perform these services. Please see new **Exhibit C- FDEP Best Management Practices** for guidelines for washing the garage.
3. Bidders will be required to submit chemical list and safety data sheets for review with bid submittal.

## EXHIBITS

Exhibit C- FDEP Best Management Practices