



# Addendum # 1



**Date:** February 24, 2025  
**To:** All bidders  
**From:** Louis Joseph, Buyer  
**Solicitation Number:** RFQ# CDS/250340  
**Solicitation Title:** **Roof Replacement – Rose Brown**

## SOLICITATION ADDITIONS, CLARIFICATIONS, AND CORRECTIONS

**NOTE: ALL INSTALLATIONS OR REPLACEMENTS MUST INCLUDE NEW PRODUCTS OR MATERIALS.**

### ITEM 1 – Roof (Line 16)

1. The Shallow roof area shall refer to low slope areas below 4:12 but no less than 2:12 pitch.