



# Addendum #1



**Date:** January 7, 2026  
**To:** All bidders  
**From:** Caley Conard, Buyer  
**Solicitation Number:** RFQ# WRS/260316  
**Solicitation Title:** Mast Arm Painting

## SECTION 1. QUESTIONS AND ANSWERS

### 1.1 **QUESTION: Is any bleach allowed to be used for cleaning, even a small percentage?**

ANSWER: No. Bleach is not allowed in any quantity. All cleaning products must be environmentally safe and fully biodegradable.

### 1.2 **QUESTION: Will the City provide water free of charge to the awarded vendor for use in cleaning the water tower?**

ANSWER: Yes. The City will provide water at no cost; however, the awarded vendor must visit Customer Service to place a refundable deposit for a water meter. This meter can then be installed on the fire hydrant near the Henry St. Water Tower.

*Note: Water is also available inside the water tower, but a backflow prevention device must be connected.*

### 1.3 **QUESTION: Are lane closures permitted on NE 8<sup>th</sup> Avenue or 9<sup>th</sup> Street**

ANSWER: Lane closures are strongly discouraged. If a lane closure becomes necessary, the Vendor must submit a Right-of-Way permit application to the City for approval. All associated costs will be the responsibility of the Vendor, and the work must comply with FDOT regulations.

The preferred staging area is inside the fenced area within the tower site.

### 1.4 **QUESTION: What is the specifications for tarping?**

ANSWER: Tarping will not be required for the fence line or the water tower. However, the Vendor must exercise reasonable care to prevent spray drift. Work should only be performed on days when the wind speed is 15 mph or less.

**1.5 QUESTION: Will paint touch up be addressed with this solicitation?**

ANSWER: No. This solicitation will only address the soft scrub, low-pressure cleaning project, and will **not** include any provisions for paint touch-up or repair.